



LICENCE CLASSES

PASSIVE FIRE PROTECTION – FIRE COLLARS, PENETRATIONS AND JOINT SEALING OCCUPATIONAL LICENCE

Licence Classes

(1) Certify

Scope of work

Certify, inspect and test— fire collars, fire rated penetrations and fire rated joint sealing.

Technical qualifications

Successful completion of —

(a) both of the following—

(i) Certificate II in Asset Maintenance (Fire Protection Equipment) PRM 20404 including the successful completion of the following competencies —

- Identify Passive Fire and Smoke Containment Products and Systems PRMPFES36A; and
- Inspect and Test Passive Fire and Smoke Containment Products and Systems PRMFES39A; and

(ii) Prepare a Fire Protection Certification Statement or Report REP 1; or

(b) successful completion of a course the authority considers is at least equivalent to a course mentioned in paragraph (a);

DEFINITIONS

Certify means

- (a) to give advice or a report, including a certificate, stating that a fire protection system complies with Australian and international standards, Building Code of Australia requirements and manufacturer’s specifications after conducting a survey of the system; and
- (b) to give a QBSA licensee certificate under the *Building Regulation 2006* for the work.

Inspect and test means

- (a) to inspect by visual examination the components of fire protection systems or equipment to establish correct settings, physical condition or fitness for purpose under 1-5-5, AS 1851-2005; and
- (b) to test, after inspecting, by the confirmation of correct function or performance of a component or system under 1-5-13, AS 1851-2005.

NOTES

(1) REP 1 is a competency unit from Certificate IV in Fire Systems Compliance 30536QLD.

Effective From	1/01/09
Scope Amendment	
Technical Amendment	